



**PUBLIC WORKS DEPARTMENT**

Timothy J. LaPorte, P.E.  
Public Works Director  
400 West Gowe  
Kent, WA 98032  
Fax: 253-856-6500

**PHONE: 253-856-5500**

**CITY OF KENT  
KING COUNTY, WASHINGTON**

**Green River Natural Resource Area (GRNRA)  
South Stormwater Pump Station  
Project Number: 17-3012**

**ADDENDUM No. 1  
September 30, 2019**

**FROM: The Office of the City Engineer, Kent Washington**  
**TO: All Plan Holders of the Project Specifications and Plans**

**This addendum forms a part of the Contract documents and modifies the Project Proposal and Specifications and Contract Drawings in accordance with the following:**

**ALL CHANGES ARE REFLECTED IN RED**

**I – PRE-BID SITE VIEWING**

The Hogan Park Lift Station will be open for Bidders to view from **1:00 PM to 4:00 PM** on **Thursday, October 3, 2019**.

**II - APPENDICES**

**Appendix 7 – Pump Station Structural, Architectural, HVAC, Electrical, and Instrumentation / Control Technical Specifications (CSI Format)**

**Section 00 01 07:** Page number on Sheet 2 is **REVISED** from 00 01 07-3 to 00 01 07-2.

**Table of Contents:** Division 5 Metals: Section 05 ~~41~~ 00 is **REVISED** to 05 **43** 00.

**ADD** the following new **Appendix 8 – Clarifications**

**Clarifications**

- 1. Clarification Regarding Product Substitution: Product substitution shall only be considered after the bid process during the submittal phase of construction.**

2. Clarification regarding PVC pipe: Unless noted specifically as SDR 21, PVC pipe shall be SDR 35.
3. Clarification regarding the lining of ductile iron fittings: For the linings of ductile iron fittings, the Kent Special Provisions take precedence over WSDOT standard specifications. All ductile iron fittings shall be epoxy lined.
4. Clarification Regarding Nuts and Bolts: Unless stated otherwise on the plans and specifications all nuts and bolts shall be stainless steel.

### **III - PLANS**

Sheet AS16 (sheet 35 of 58): The title is revised as follows:

Maintenance Garage Building ~~Elevations~~ **Enlarged Plan**

**END OF ADDENDUM No. 1**



Chad Bieren, P.E.  
Deputy Director/City Engineer



Date