

PUBLIC WORKS



ADDENDUM NO. 4 TO 2020 TRICKLING FILTER MEDIA REPLACEMENT W.O. # UT-3742-2 MAY 27TH, 2020

NOTICE TO PLANHOLDERS

Addendum No. 4 contains the following revisions, additions, deletions and clarifications and is hereby made a part of the contract documents for the above-named Project and shall be considered by all prospective bidders in submitting bids.

Bidders must acknowledge receipt of Addendum No. 4 in the space provided on page 00 4113 -3 in the Bid Form. Failure to comply with this requirement may render the Bid non-responsive and may cause its rejection.

This Addendum No.4 consists of 2 pages, including all revisions, attachments and details.

The Bid date for receipt of Bids is not changed by this Addendum.

ANSWERS TO QUESTIONS SUBMITTED FOR CLARIFICATION

- Q1 - Does the washdown and cleaning water have to be disposed of offsite? - *In discussions with WPCF staff, if it is screened, the washdown and cleaning water can be pumped approximately 50 ft. to the East, into the City's Aeration Pond #1. All debris and plastics must be removed prior to pumping and the pump must have an inlet screen size no larger than 1/4 of an inch.***

** Reminder, due to Covid19 the sealed bids must be sent/delivered to the City's Purchasing Department where the bid opening will be streamed on-line. The address is City of Everett Purchasing Department, 3200 Cedar Street, Door #5, Everett WA 98201.

Door #5 can be found on the west side of the Public Works Building.

The link for the webcast is located at <https://www.everettwa.gov/319/purchasing>