

## WPTP Primary Sedimentation Area Roof Structure

Contract Number C01398C20

### CLARIFICATION 4

Prospective bidders are hereby notified that pursuant to §00100-1.02, King County provides the following questions and responses as clarifications of the referenced Contract Documents. This Clarification form and these clarifications herein are not part of the Contract nor part of the Contract Documents.

Ref.	Section and Page or Drawing	Questions and Responses
1.	Spec Section 26 08 00	<b>Q.</b> Please verify that 3rd party testing NETA certified contractor is required for insulations testing and all low volt conductor and cable test per section 26 08 00. <b>R.</b> 3rd party testing and commissioning is not required if the Contractor is NETA certified.
2.	Spec Section 41 22 23.19	<b>Q.</b> Addendum 5, 5.7, 5. Power Supply - 120V 1 phase - appears to match the electrical drawings, however, is not available in a wire rope design as specified. Would chain hoists be acceptable? <b>R.</b> Please see Addendum 7 for change.

This Clarification will not form a part of the Contract Documents. Bidders are reminded to review addenda for changes to the Invitation to Bid documents.

Issue date: 12/16/2020

Contract Specialist: Megan Saunders, [megsaunders@kingcounty.gov](mailto:megsaunders@kingcounty.gov), 206-263-6813

Back-Up Contract Specialist: Liz Evans, [levans@kingcounty.gov](mailto:levans@kingcounty.gov), 206-263-7898