



**ADDENDUM NO. 01**

**Project:** ITB 21-02: Industrial Pretreatment Lagoon Upgrades

**Date:** January 15, 2021

This Addendum shall become as fully a part of the above-named project Scope of Work, specifications, deliverables, minimum requirements or qualifications, drawings, and other requirements as if therein written and shall take full and complete charge over anything therein written contained to the contrary. Each bidder shall be responsible for reading this Addendum to ascertain to what extent and in what manner it affects the work to be performed.

---

**THIS ADDENDUM DOES NOT CHANGE THE BID OPENING DATE.**

**Bid Opening Instructions:**

- Be advised Bid opening will be held via an online platform. Contractors are invited to join through the website or by phone:

**Online:**

<https://covwebex.webex.com/covwebex/j.php?MTID=m5f60fa613b5ddffc639281d36d643a37>  
Meeting password: Bidopening

**By Phone:**

(408)418-9388  
Meeting number (access code): 146 078 0498

**Revised Document:**

- Page 2, Revised ITB Schedule which replaces the ITB Schedule section from the original Bid Documents

<b>Event</b>	<b>Date</b>
<b>Pre-Bid Meeting</b>	<b>Wednesday, January 13, 2021 at 10:00 AM</b>
<b>Questions Due by 5:00pm PST</b>	<b>Wednesday, January 26, 2021</b>
<b>Addendum Issuance by 5:00pm PST</b>	<b>Tuesday, February 2, 2021</b>
<b>Bid Opening at 11:00am PST</b>	<b>Tuesday, February 9, 2021</b>

### Questions and Answers:

- Question:** Could you please consider changing this sentence as follows?  
Stainless steel slide candidate gate manufacturers include Fontaine, Golden Harvest, Whipps, **Rodney Hunt** or equal, modified to meet specified requirements.  
Rodney Hunt has been an established manufacturer of water control products including stainless steel slide gates for over 100 years and has thousands of installations US and worldwide

**Answer:** The City will not be including Rodney Hunt in the above sentence. The awarded contractor will have an opportunity to propose an alternative supplier of Gates upon construction submittals.
- Question:** We would like to request that the following products be included to bid as a or equal: Post Glover HRG in Section 26 059 5 11 and Ermco pad-mounts in Section 26 12 19.

**Answer:** The City will not be including Post Glover and Ermco in the bid as an alternative. The awarded contractor will have an opportunity to propose an alternative supplier with construction submittals.
- Question:** Will this job require any sludge removal or temporary dewatering?

**Answer:** No, the job will not require sludge removal (or temporary dewatering).

### Corrections:

- Error:** In the Plans, according to the Index Sheet D-505 Mechanical Details - 5 is actually Mechanical **Detail - 4** on the Sheet.

**Correction:** Correct, will revise annotation.
- Error:** In the Specs, Section 013300-A Submittal Transmittal Form & Section 430511-A Manufacturer's Installation Certification Form is Missing according to the list on Section 019990 Reference Forms (page 194).


**Correction:** This form is in the documents. Page 206 / 843. All of the required forms are there, they are just not in the proper order.
- Error:** In the Specs, Section 261113.11 is Missing according to the Table of Contents on page 115.

**Correction:** Section 26 11 13.11 is not required. Delete reference to 26 11 13.11 from the Table of Contents.
- Error:** Section 400559.23 has Fabricated spelled wrong on page 696

**Correction:** Noted and will correct.
- Error:** Section 407500 is duplicated (Pages 767-771 & 807-811)

**Correction:** Delete first instance of Section 40 75 00 (Pages 767-771).

### APPROVALS:



**Date: 1/15/2021**

**Patrick Murphy, Procurement Specialist**