

Contract XE3671 - I-5/Koontz Rd Bridge - Emergency Bridge Repair

Question & Answer | Date: 11/14/25

Email Bid Questions To: ChehalisQA@wsdot.wa.gov

Question Number	Reference Existing Contract Page # or Addenda	Question	WSDOT Response
1	SS 1-07.18(5)	Our insurance carrier is requesting the following information for our OCP quote. Could you please provide? Please confirm the OCP limit - assuming it would be \$5M.	refer to the contract documents - Standard Specifications for Road, Bridge, and Municipal Construction 1-07.18(5)
2	PG BG16 & BG17	1. Sheets BG16 and BG17 show an architectural formliner finish on the backside of the barrier, but it appears that the existing barrier is smooth finish. Is WSDOT wanting the new section of barrier to have a different finish than the existing? 2. Is there conduit in the barrier than we are removing/replacing?	1. Bid in accordance to the plans. The existing barrier is not smooth. 2. Bid in accordance to the plans. BG16 detail D shows no conduit.