



City of Tacoma

**Environmental Services Department
Science and Engineering Division**

ADDENDUM NO.1

DATE: March 31, 2026

REVISIONS TO:

Request for Bids Specification No. ES26-0002F

Central Wastewater Treatment Plant Mixed Liquor Channel Pipe Replacement Project

NOTICE TO ALL BIDDERS:

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

REVISIONS TO THE SUBMITTAL DEADLINE:

The submittal deadline remains 11:00 a.m., Pacific Time, Tuesday April 7, 2026.

REVISIONS TO THE TECHNICAL SPECIFICATIONS:

Change No. 1 Revision to Section 05_50_00 – METAL FABRICATIONS

REPLACE 2.01.A.1 in its entirety with the following:

Sheets and Plates: ASTM A240, Type 304

Change No. 2 Revision to Section 05_50_00 – METAL FABRICATIONS

REPLACE 2.01.A.2 in its entirety with the following:

Shapes, bars, and similar items: ASTM A276, Type 304 or ASTM A1069 for laser-fused shapes.

Change No. 3 Revision to Section 05_50_00 – METAL FABRICATIONS

REPLACE 2.01.A.3 in its entirety with the following:

Bolts: ASTM F593C or F593D as required by size.

Change No. 4 Revision to Section 05_50_00 – METAL FABRICATIONS

REPLACE 2.01.A.4 in its entirety with the following:

Nuts: ASTM F594C or F594D as required by size.



City of Tacoma

Change No. 5 Revision to Section 05_51_33 – METAL STAIRS: CROSSOVER STAIRS

REPLACE 2.02.A.2 in its entirety with the following:

Finish: Mil finish per manufacturer

Change No. 6 Revision to Section 05_51_33 – METAL STAIRS: CROSSOVER STAIRS

REPLACE 2.02.B.1 in its entirety with the following:

Galvanized or Aluminum steel treads and grating.

Change No. 7 Revision to Section 40_05_00.09 - ATTACHMENT A – PIPING SYSTEM TESTING SCHEDULE

REPLACE Spray Water Header - Pipe Material & Size in its entirety with the following:

4" 316 SS Sch 10S, Victaulic Grooved.

REVISIONS TO THE DRAWINGS:

Change No. 8 Revision to Drawing M10 Sheet 26:

REPLACE Material callout in its entirety with the following:

Replace existing ductile iron pipes with thickness class 53 unlined ductile iron.

Change No. 9 Revision to Drawing GM01 Sheet 16:

REPLACE Plan Note 1 in its entirety with the following:

1. CONTRACTOR TO APPLY PIPE FIELD LABELS ON ALL NEW PIPING WITHIN PROJECT BOUNDARY USING LABEL COLOR AND TEXT COLOR FOLLOWING TABLE ABOVE, ALL OTHER ASPECTS OF PIPE FIELD LABELS SHALL FOLLOW ANSI/ASME A13.1.

Change No. 10 Revision to Drawing GM01 Sheet 16:

REPLACE Plan Note 2 in its entirety with the following:

2. CONTRACTOR TO COAT AND LABEL ALL NEW EXTERIOR CPVC PIPING WITHIN BOUNDARY OF PROJECT. APPLY ONE COAT OF PPG BREAK-THROUGH WATERBORNE ACRYLIC SEMI-GLOSS PAINT V62 SERIES, MINIMUM 1.5 MILS DFT TO ALL CPVC PIPING SURFACES, FITTINGS, AND VALVES. CONTRACTOR TO MATCH PAINT COLOR AND FIELD LABEL NOMENCLATURE PER THE PLAN NOTES AND THE TABLE ABOVE. ALL SURFACES SHALL BE PREPARED FOLLOWING MANUFACTURING REQUIREMENTS PRIOR TO COATING.



City of Tacoma

Change No. 11 Revision to Drawing G03 Sheet 3:

REPLACE Note in its entirety with the following:

NOTE:

BECAUSE OF UNDERGROUND UTILITIES AND UNSTABLE SOILS, CONTRACTOR VEHICLES AND EQUIPMENT ARE PROHIBITED FROM ACCESSING THE GRASS AREAS ADJACENT TO CLARIFIERS #1, #3, AND #5 UNLESS GROUND PROTECTION MATS OR STEEL ROAD PLATES ARE USED TO DISTRIBUTE LOADS. THE CONTRACTOR IS RESPONSIBLE FOR REPAIRING OR REPLACING ANY DAMAGED LANDSCAPING, UTILITIES, CURBING, OR ROAD SURFACES IN PROJECT AREA AT THEIR OWN EXPENSE.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the signature page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. ES26-0002F Addendum No.1. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

cc: Lance Bunch, P.E., ESSE