

ADDENDUM NO. 2
TO THE CONTRACT DOCUMENTS
for the construction of
Salmon Creek Treatment Plant UV System Replacement Project

Date: April 16, 2026
Jacobs Project No. D3454455
DCWA Project No. 93-2023-0048

To All Plan holders and/or Prospective Bidders:

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the construction of Salmon Creek Treatment Plant UV System Replacement Project, dated January 2026 as fully and completely as if the same were fully set forth therein:

- A. VOLUME I, SPECIFICATIONS – NO CHANGES
- B. VOLUME II, SPECIFICATIONS – NO CHANGES
- C. VOLUME III, GEOTECHNICAL DATA REPORT – NO CHANGES
- D. VOLUME IV, PLANS
 - 1. 99-D-512 PROCESS STANDARD DETAILS – 2
 - a. Add to detail 4027-201: NOTE: 1. V915 – CAST STAINLESS STEEL MUD VALVE 4 INCHES TO 20 INCHES: A. HEAVY-DUTY CF8M STAINLESS STEEL YOKE, FLANGE, GUIDES AND GATE; BUNA-N SEAT MECHANICALLY RETAINED WITH TYPE 316 STAINLESS STEEL FASTENERS, RISING STEM. STAINLESS STEEL CASING TO BE PASSIVATED PER ASTM A380. TYPE 316 STAINLESS STEEL ONE-PIECE STEM WITH INTEGRAL THRUST COLLAR AND COATED WITH ANTIGALLING COMPOUND. B. VALVE STEM EXTENSION TYPE 316 STAINLESS STEEL STEM WITH 2-INCH OPERATING NUT C. MANUFACTURERS TROY VALVE OR TRUMBULL INDUSTRIES INC.
- E. VOLUME V, PRE-SELECTED EQUIPMENT QUOTE AND SUBMITTALS TROJAN TECHNOLOGIES / SECTION 44 44 73 – NO CHANGES

This Addendum does not change the date or time of when bids are due. All Bidders shall acknowledge receipt and acceptance of this Addendum No. 2 in the Bid Form. Bid Forms submitted without acknowledgment will be considered in nonconformance.

Clark Regional Wastewater District

Chris Stangl
Construction Manager

Appended hereto and part of Addendum No. 2 - none

Appended hereto and not part of Addendum No. 2 -
none

END OF ADDENDUM NO. 2