

Eastrail to NE Spring Boulevard Trail Link

Bid Number 26012

Questions and Answers

5/06/2026

Q1: Sheet WA07 - Please confirm finish requirement for this Pedestrian Railing, notes do not indicate.

A1: The Pedestrian Railing shall be galvanized per the Materials Table on WA07. After galvanizing it shall be painted or powder coated per Note 8 on Revised Sheet WA07. The Stair Handrail on Sheet ST02 shall also be painted or galvanized per Note 10 on Revised Sheet ST02. Please see Addendum No. 1.

Q1: WSDOT STD Plan L-5.15, note 19 states this rail should not be installed on horizontal curves, such as wall 2. This is due to cable tensioning pressure side loading the posts. Is it not appropriate to use a standard two rail pipe railing such as City of Seattle detail 442 in lieu of the WSDOT design? This would closely match the stair railing.

A1: The Wall 2 Cable Fence is revised to be Bridge Railing Type Chain Link Fence Rail per WSDOT Standard Plan L-5.10 and shall be powder coated or painted after galvanizing. Please see Addendum No. 1.