



ADDENDUM NO. 2

Project: ITB #26-19: Water Station 1 – Wellhouses 3B & 5B

Date: May 14, 2026

This Addendum shall become as fully a part of the above-named project Scope of Work, specifications, deliverables, minimum requirements or qualifications, drawings, and other requirements as if therein written and shall take full and complete charge over anything therein written contained to the contrary. Each bidder shall be responsible for reading this Addendum to ascertain to what extent and in what manner it affects the work to be performed.

THIS ADDENDUM CHANGES THE DUE DATE FOR BIDS TO TUESDAY, JUNE 2, 2026.

TECHNICAL SPECIFICATIONS (Changes are noted in bold italics):

Section 15.02 Metal Pipe and Fittings, subsection 15.2.02 Ductile Iron Pipe and Fittings, Part 1 – General, Design Requirements is revised to read:

Ductile iron pipe shall have thickness designed in accordance with ANSI/AWWA C150/A21.50 and shall be based on laying conditions and internal pressures to meet the requirements of Division 1.81.40 unless listed as more stringent below.

The pipe thickness shall not be less than that of Class **55 52** pipe for non-flanged pipe.

The pipe thickness for fire hydrant runs shall not be less than Class 52.

Flanged joints shall conform to ANSI Standard B16.1 and be of the class shown on the plans.

APPROVALS:

Date: 5/14/2026

Anna L. Vogel, Procurement Manager