

Covington Water District

ADDENDUM No. 2

Date of Issue: June 29, 2026

To all prospective bidders for the Work titled: **222nd PLACE CORROSION CONTROL FACILITY REHABILITATION**, issued for bid by the Covington Water District on June 2, 2026.

The Drawings and Specifications and Addendum No. 1 are modified as follows. This Addendum No. 2 forms a part of the Contract Documents and modifies the original documents.

This Addendum consists of 2 pages.

Note: The bid date is unchanged. Sealed bids will be received by Covington Water District until 10:00 AM, July 1, 2026.

CHANGES TO SPECIFICATIONS

Specification Section 09679:

1. Replace line 2.02, B, 3 with the following:

“Horizontal base coat: Tek-Crete SL or Poly-Crete SL. Vertical Base Coat: Dex-O-Tex Base Coat Neobond FRM system or Poly Crete TF Plus system.”

2. Replace paragraph 3.02, A, 2, a with the following:

“Perform relative humidity test using in situ probes, ASTM F2170 or MVER test per ASTM D4263 or ASTM F1869. Proceed with installation only after substrates comply with the coating manufacturer’s requirements.

3. Add the following sentence to the end of paragraph 3.04, D:

“Apply specified vertical coating system above the cove per the manufacturer’s recommended coating thickness.”

Tom Malphrus, PE

Tom Malphrus

CIP Supervisor
Covington Water District
18631 SE 300th Place
Covington, WA 98042
253-867-0906 – Direct Line
253-631-0565 - Covington Water District Office

BIDDER ACKNOWLEDGEMENT:

Bidder shall either sign here and submit this form with the bid proposal or complete the acknowledgement of addendums section on the Schedule of Prices form submitted with the Bid.

Signature: _____
Jeff Carlsen

Date: 06/29/2026