

ADDENDUM NO. 01**CTUIR/COU JOINT PUMP AND PIPELINE PROJECT - INTAKE AND PUMP STATION
CITY OF UMATILLA**

Addendum No. 01 to the **CTUIR/COU Joint Pump and Pipeline Project - Intake and Pump Station** Plans, Specifications, and Contract Documents prepared by **Kleinschmidt Associates, Inc.**, is hereby submitted for use in bid preparation and submittal.

The following changes, additions, and/or deletions are hereby made as part of the **CTUIR/COU Joint Pump and Pipeline Project - Intake and Pump Station**, dated May 2026, as fully and completely as if the same were entirely set forth in the Plans, Specifications, and Contract Documents. Changes and additions are noted in ***bold italics***, and deletions are noted in ~~strikethrough~~.

CLARIFICATIONS**Purpose of Addendum**

The purpose of this addendum is to respond to questions from potential bidders.

Questions and Clarifications

1. Q: We manufacture metal roofing and siding in the Pacific Northwest, and I am hoping that you would be able to entertain a substitution request for the Metal Roof Panels & Metal Wall Panels on this project?

A: Alternative products will not be reviewed or evaluated during bidding. Roofing and siding supplied by alternative manufacturers will be evaluated during the submittal review process and may be acceptable.

2. Q: I see that the projected timeline is September 2026 to December 2028. Is there a more narrowed down idea of when NTP will be issued. Also, is there a set number of working days?

A: NTP is currently anticipated to be issued in mid-August 2026. There is not a set number of working days. See Specification Section 01 32 16 for milestone dates and schedule constraints.

3. Q: Can CAD files please be made available for this CTUIR/COU Joint Pump and Pipeline Project Intake and Pump Station project?

A: No, CAD files will not be provided during bidding.

4. Q: Will the owner be responsible for providing fuel for the generator?

A: The Contractor needs to provide fuel for startup, testing, and commissioning of the generator and use of the generator during overall project commissioning.

5. Q: Can you confirm the instrumentation and controls equipment is by the contractor?

A: Yes, the I&C equipment is to be provided by the contractor.

6. Q: is there a list of pre-approved control system integrators?

A: No, there are no pre-approved integrators.

7. Q: Can you confirm the programming of the control system/SCADA is by the owner?

A: Programming of the pump operations will be by the owner. All other programming is to be by the contractor.

8. Q: Could you please clarify the scope of work for the 30" and 36" pipeline? I would like to confirm whether the specifications call for HDPE or welded steel pipe?

A: Both steel and HDPE pipe materials are included in the project. See drawing 230-01 for the location of the steel to HDPE transition.

VOLUME I – CONTRACT DOCUMENTS AND SPECIAL PROVISIONS

No changes.

VOLUME II – TECHNICAL SPECIFICATIONS

No changes.

VOLUME III – PLANS


No changes.

Acknowledgment of Addendum

All Offerors must acknowledge receipt of this Addendum by including a signed copy with their bid submission or by acknowledging it in the manner specified in the Solicitation Document.

Submitted by:

Kleinschmidt Associates, Inc.



Charles W. Cutting, P.E.
Project Engineer

DATE: 06/12/2026

Notice is hereby given that this addendum must be acknowledged on the Bid Proposal, failure to do so may result in your bid being considered as irregular and may be rejected.

NAME OF BIDDER: _____

SIGNED BY: _____ DATE: _____
NAME AND TITLE